

## no. 230.11– 02 ES2010

**Declaration of conformity issued by**

Trade name: ASIO spol. s r.o.  
Registered office: Jiříkovice 83, 664 51 Jiříkovice  
Company ID: 48910848

**as the manufacturer of the product**

Product name: type range of wastewater treatment plants  
Type: AS VARIOcomp

**Description of the product:**

Mechanical-biological activation wastewater treatment plant of 3 to 55 PE (according the WWTP size).

**List of standards and European technical approvals the product is in compliance with:**

ČSN EN 12566-3 + A1:2009

**Certificates of tests performed by Authorised Body:**

Report on Initial Type Testing of the Product no. 1020-CPD-090-024485  
issued by Technický a zkušební ústav stavební in Prague, Notified Body no. 1020,  
Prosecká 76, Praha 9, Company ID 00015679

**Specific condition of use:**

Not stated

<b>CE</b>			
ASIO spol. s r.o., 664 51 Jiříkovice 83 Company ID: 48910848			
10 <b>ČSN EN 12566-3 + A1:2009</b> <b>AO 204, NO 1020</b>			
AS VARIOcomp ..ROTO ; AS VARIOcomp ..K ; AS VARIOcomp ..N ; AS VARIOcomp ..ROTO P ; AS VARIOcomp ..K P ; AS VARIOcomp ..N P ;			
Hydraulic daily load (m <sup>3</sup> /day):	0,60; 0,75; 1,20; 2,25; 3,00; 4,05; 5,70; 7,50 *		
Material:	PP-polypropylene ; PE* - polyethylene		
Watertightness (water test):	Complies		
Crushing resistance:	Complies		
Durability:	Complies		
Treatment efficiency** :	Index	Values at outlet mg/l	%
	BOD <sub>5</sub>	11,8	96,0
	COD	85,0	85,0
	TSS	29,0	90,3
	P <sub>total</sub>	- / 0,35***	- / 96,6***

\*..... according to size and version of WWTP

\*\*..... initiate values were measured during exam treatment efficiency according to standard ČSN EN 12566-3:2006

\*\*\*..... AS VARIOcomp..ROTO; AS VARIOcomp..K; AS VARIOcomp..N / AS VARIOcomp..ROTO P; AS VARIOcomp..K P; AS VARIOcomp..N P

In Brno dated 01<sup>th</sup> November 2010

Ing. Oldřich Pírek  
Owner of ASIO spol. s r.o.